

EPL Reference: EPA1	
Site Reference: Clean Water Dam Licensed Discharge Point	
Location (GDA20 Zone 56): 282639 m E 6494733 m S	
Monitoring Frequency: On Discharge (once during every 6 month period during discharge)	

Date	Rainfall (mm) (preceding 5 days)		Oil & Grease (mg/L)		Conductivity (µS/cm)		pH		Total Suspended Sediment (mg/L)		Comments
	5-day Threshold ¹	Result	Criteria	Result	Criteria	Result	Criteria	Result	Criteria	Result	
4/05/2021	54.2	Not recorded	None	<5	None	413	None	8.6	50	13	

No discharge events have occurred since May 2021

Notes
 1: Refers to the 5-day 95th percentile rainfall event (design rainfall event for sediment basins within sensitive receiving environments) for Tamworth

Legend
 Values identified in red represent results exceeding criteria requiring notification to the NSW EPA as a pollution incident.
 Shaded values represent results exceeding criteria recorded under conditions where criteria are not applicable, i.e. TSS concentration > 50 mg/L following rainfall exceeding 54.2 mm in five days.

